



Harford County Public Schools

102 S. Hickory Avenue Bel Air, MD 21014

410.638.4082

Fax 410.638.4304

Dr. Robert M. Tomback, Superintendent of Schools
Purchasing Department

Addendum #1

To: All Bidders

From: Donald A. Gunther
Purchasing Department

Subject: Bid 12-DGC-013
Emergency Generator - Forest Hill Annex
Additional Information

Date: February 7, 2012

Inquiry: **1.10 Coordination B.:**

'Coordinate with existing ATS switch connections and controls' – please provide existing ATS manufacturer, model and serial number of ATS on site. Due to the age of existing ATS may not be compatible with new replacement generator.

RESPONSE: The existing ATS is a recently installed (circa 2010) made by Emerson Network Power - ASCO Series 300

Inquiry: **2.6 Generator Circuit Breaker A.:**

Please provide amperage of circuit breaker needed on generator.

RESPONSE: The generator mounted circuit breaker shall be a 3 pole 400 ampere adjustable trip setting circuit breaker.

Inquiry: **2.9 Outdoor Generator Set Enclosure D.:**

'...to meet specified sound level requirements'. Cannot locate specified sound level within the written specifications. Kohler manufacturer will provide 72dBA @ 23 Feet In A Free Field Environment. Please accept this sound attenuation to be sufficient.

RESPONSE: Sound level of 73 dBA at 23 feet shall be acceptable for Outdoor Generator set enclosure.

Inquiry: **3.1 Start-Up D.:**

1. NETA Acceptance Testing is conducted by the electrical contractor. Suppliers do not provide this service. Please clarify NETA testing will be performed by others.

RESPONSE: The Owner's electrical contractor shall provide the acceptance testing. The generator supplier shall provide certified field technician to be on-site during all testing and demonstrations.

Inquiry: **3.3 Commissioning B.**

'Fuel to be provided for testing, re-testing and demonstrations'. Suppliers do not provide fuel – end user and or electrical contractor installing component provides fuel. Please clarify fuel will be provided by others.

RESPONSE: The Owner's electrical contractor shall provide the fuel. The generator supplier shall provide certified field technician to be on-site during all testing and demonstrations.

Addendum #1
Emergency Generator – Forest Hill Annex
Page 2

Any questions concerning this addendum should be forwarded to Donald Gunther at 410.638.4339 or e-mail to Don.Gunther@hcps.org.

I hereby acknowledge receipt of Amendment #1 dated February 7, 2012 Bid #12-DGC-013 for Emergency Generator – Forest Hill Annex.

Company

Name (Print or Type)

Address

Title

Signature

Telephone

Date

Fax

Note: Proposer shall sign and submit a copy of this addendum with their proposal form.