

Facilities Management

Patti Jo Beard, Executive Director

Phone 410 638-4088 • Fax 410-638-4205

Lead in Drinking Water – Public and Nonpublic Schools

IMPORTANT NOTICE: ELEVATED WATER SAMPLE RESULT **Homestead-Wakefield Elementary School (Wakefield building)**

ELEVATED LEAD WATER SAMPLE RESULT

All Maryland public and nonpublic schools are required to sample all drinking water outlets for the presence of lead pursuant to the Code of Maryland Regulations. On October 30 and 31, 2018, one hundred twenty (120) lead water samples were collected from Homestead-Wakefield Elementary School (Wakefield building). Of these lead water samples, **four** had levels of lead exceeding the action level of 20 parts per billion (ppb) for lead in drinking water in school buildings. The elevated lead results from the samples collected at Homestead-Wakefield Elementary School (Wakefield building) were as follows:

- 25.5** parts per billion (ppb) **Room 14 sink**
- 20.1** parts per billion (ppb) **Reading Room sink**
- 37.9** parts per billion (ppb) **Reading Room fountain**
- 31.2** parts per billion (ppb) **Boy's restroom by Room 14, third left sink**

ACTION LEVEL (AL)

The AL is 20 ppb for lead in drinking water in school buildings. The AL is the concentration of lead which, if exceeded, triggers required remediation.

HEALTH EFFECTS OF LEAD

Lead can cause serious health problems if too much enters your body from drinking water or other sources. It can cause damage to the brain and kidneys, and can interfere with the production of red blood cells that carry oxygen to all parts of your body. The greatest risk of lead exposure is to infants, young children, and pregnant women. Lead is stored in the bones and it can be released later in life. During pregnancy, the fetus receives lead from the mother's bones, which may affect brain development. Scientists have linked the effects of lead on the brain with lowered IQ in children. Adults with kidney problems and high blood pressure can be affected by low levels of lead more than healthy adults.

SOURCES OF HUMAN EXPOSURE TO LEAD

There are many different sources of human exposure to lead. These include: lead-based paint, lead-contaminated dust or soil, some plumbing materials, certain types of pottery, pewter, brass fixtures, food, and cosmetics, exposure in the work place and exposure from certain hobbies, brass faucets, fittings, and valves. According to the Environmental Protection Agency (EPA), 10 to 20 percent of a person's potential exposure to lead may come from drinking water, while for an infant consuming formula mixed with lead-containing water this may increase to 40 to 60 percent.

IMMEDIATE ACTIONS TAKEN

Results were received on March 5, 2019. Water has been turned off at the sinks and drinking fountain.

NEXT STEPS

At this time our remedial action will be to permanently disconnect the sinks and fountain. If the fixtures are replaced and the results are below the action level, the fixtures will be placed back in service.

TO REDUCE EXPOSURE TO LEAD IN DRINKING WATER:

1. Run your water to flush out lead: If water hasn't been used for several hours, run water for 15 to 30 seconds or until it becomes cold or reaches a steady temperature before using it for drinking or cooking.
2. Use cold water for cooking and preparing baby formula: Lead from the plumbing dissolves more easily into hot water.

Please note that boiling the water will not reduce lead levels.

ADDITIONAL INFORMATION

1. For additional information, please contact **Patti Jo Beard, Harford County Public Schools**, at **410-638-4088**. For additional information on reducing lead exposure around your home/building and the health effects of lead, visit EPA's website at www.epa.gov/lead. If you are concerned about exposure; contact your local health department or healthcare provider to find out how you can get your child tested for lead.